




Electrical Bulletin – QO Panel Defect

June 16th, 2022

Re: Panels not Approved

This is to notify all contractors of the Schneider Electric (Square D) panel recall. Affected panels are from the QO plug on neutral series. To identify a defective panel:

1. Manufacturing plant code is 15
2. Catalog number is on the affected list included in this bulletin
3. Date codes are from Feb 1, 2020 to Jan 12th 2022 starting with 200561 and ending at 220233



We cannot approve the installation of these panels as they have been identified as a potential fire hazard.

For more detailed information:

<https://recalls-rappels.canada.ca/en/alert-recall/various-square-plug-neutral-pon-loadcentres-schneider-electric-recalled-due-potential>

Schneider Electric Technical Support: 1-888-778-2733. Options 2, 1, and 4.

Thank you,

Logan Collins

A/ Chief Electrical Inspector

Community Services | Building Safety

T 867-667-5485 | C 867-332-4825 | Yukon.ca