



Section 26

Single Family Dwellings

Each single family dwelling shall be provided with the following:

- 1) A 20-amp vehicle heater receptacle on a dedicated circuit that complies with requirements of the C.E.C.; and
- 2) A 1” conduit from the main electrical panel to a designated parking space to accommodate the future install of an EV charger

26-722 b) Receptacles required by this rule also include areas such as decks, verandas, patios and any other outside living area large enough to accommodate outdoor appliances and/or furniture.

Panelboards

Panelboards may only be located in an outside wall if their install does not impact the building envelope or reduce the insulation value at the location below a minimum R28 value.

Panelboards shall not be located within 1.5m of sinks

Usable Wall Space

Wall sections occupied by baseboard heaters are defined as usable wall space when installing receptacles in dwelling units.

“Split stud” sections of wall constructed to accommodate the opening of a pocket door are defined as usable wall space when installing receptacles in dwelling units