



Section 76

Temporary services

All temporary services must be constructed using weatherproof parts and equipment, even when installed within a wooden enclosure. (ref. Bulletin 16-1)

Underground temporary services are permitted to be installed on a sandwich board provided the legs are fastened in a manner that prevents accidental collapse of the service.

Temporary services are to be kept in good working order and must comply with the current edition of the Canadian Electrical Code before they will be connected.