



Section 8

Single Family Dwellings

When completing a load calculation for a single family dwelling, the 1” conduit installed to accommodate an EV charger does not need to be included unless a EV charger has actually been installed. (ref. Bulletin 22-1)