



Section 62 Fixed Electric Heating Systems

Heat Trace

All heat trace must be ground fault protected. This is best accomplished by a GFI breaker and not a GFCI receptacle. GFCI plugs are too sensitive and interrupt the circuit at 5 mA which can result in nuisance tripping. GFI breakers with a trip threshold of 30 mA are to be used to protect equipment.