





Electrical Bulletin – Universal FSU Boxes

March 15, 2022

Re: FSU boxes only approved for dry locations

We have received an updated product catalogue showing that ABB Universal FSU boxes are now approved for dry location only. We will continue to accept their installation in wet locations on any existing permits, but all future permits will require that these boxes meet the new manufacturer specifications for use.

Here is a picture and Cat. No. of the referenced box type for clarity:

Universal FSU boxes – 2 1/4 in. deep (cast aluminum)					
	Cat. no.	Hub size (in.)	No. of gangs	No. of lugs	Std. ctn.
	CIFSU-1/2	2 x 1/2	1	2	20
	CIFSU-3/4	2 x 3/4	1	2	20

For dry location only

Supplied with close up plugs **For dry location only.**

Please consult your wholesaler for alternative products for wet locations.

If you have any questions regarding this bulletin, please do not hesitate to contact our department.

Thank you,



Logan Collins
 A/ Chief Electrical Inspector
 Community Services | Building Safety
 T 867-667-5485 | C 867-332-4825 | Yukon.ca