



Section 10

Bonding of gas piping systems

Bonding of gas piping systems should not interfere with any cathodic protection forming part of the gas piping system. The bonding of the gas line should therefore be made on the consumer side of the gas meter. It is recommended that the gas piping system be bonded to the main distribution panel, the grounding conductor or the grounding electrode.

Isolated neutral meter enclosures

Individual meter enclosures are required to have the neutral conductor isolated in the meter enclosure and grounded at the first point of disconnect.

Multi-meter enclosures are to have the neutral grounded within the meter enclosure. (ref. Bulletin 22-2)